

Panhandle Health District I
ON-SITE SEWAGE SYSTEM PERMIT

Septic Permit # SP 99-28-0328

Issue Date 06/15/1999

This permit is valid for one year from issue date for an individual subsurface sewage disposal system for:

Parcel # 0-2200-00B-010-A, Township 51N, Range 03W, Section 16, Boise Meridian; Lot 10, Block B of ENGLISH POINT; a acre plot currently belonging to ELSIE MATTHEWS. The system has been sized for a 1700 square foot single family residence with 3 bedrooms and 1 baths.

The following conditions are placed upon the permit:

SEPTIC TANK-

- Tank Capacity will be at least 1000 gallons

DRAINFIELD (or replacement area)-

- The following Alternative System Design will be used - Graveless System
- Length of system will be 84 feet
- Graveless Trench Type - Dome Chamber

CONDITIONS-

Existing system must be abandoned after completion and connection of new system.

Drainfield must follow the contour of the native slopes.

Sewer lines / Effluent Lines must be double encased under roadways.

No parking, driving, structures or livestock over the drainfield or replacement area.

Manufacturer's Recommendations must be followed on all components.

Maintain all separation distances listed on the permit and/or listed within the Technical Guidance Manual for Individual and Subsurface Sewage Disposal.

This is a repair/replace best possible upgrade. It will still not meet today's standards. Replacement area available just below driveway scarp if needed.

SEPARATION DISTANCES:

- Distance of tank from dwelling foundation - 5 feet minimum
- Distance of tank from well - 50 feet minimum
- Distance of tank from private water lines - 10 feet minimum
- Distance of tank from public water lines - 25 feet minimum
- Distance of field from property line - 5 feet minimum
- Distance of field from dwelling foundation - 20 feet minimum
- Distance of field from well - 100 feet minimum
- Distance of field from surface water - 300 feet minimum
- Distance of field from septic tank - 6 feet minimum
- Distance of field from water lines - 25 feet minimum
- Drainfield must not exceed 4 feet in depth unless specified alternative system

Panhandle Health District I

ON-SITE SEWAGE SYSTEM PERMIT

Installer's Copy

Septic Permit # SP 99-28-0328

Issue Date 06/15/1999

This permit is valid for one year from issue date for an individual subsurface sewage disposal system for:

Parcel # 0-2200-00B-010-A, Township 51N, Range 03W, Section 16, Boise Meridian; Lot 10, Block B of ENGLISH POINT; a acres plot currently belonging to ELSIE MATTHEWS.

The following conditions are placed upon the permit:

SEPTIC TANK-

- Tank Capacity will be at least 1000 gallons

DRAINFIELD (& replacement area)-

- The following Alternative System Design will be used - Graveless System
- Length of system will be 84 feet
- Graveless Trench Type - Dome Chamber

CONDITIONS-

Existing system must be abandoned after completion and connection of new system.

Drainfield must follow the contour of the native slopes.

Sewer lines / Effluent Lines must be double encased under roadways.

No parking, driving, structures or livestock over the drainfield or replacement area.

Manufacturer's Recommendations must be followed on all components.

Maintain all separation distances listed on the permit and/or listed within the Technical Guidance Manual for Individual and Subsurface Sewage Disposal.

This is a repair/replace best possible upgrade. It will still not meet today's standards.

Replacement area available just below driveway scarp if needed.

Panhandle Health District I

ON-SITE SEWAGE SYSTEM PERMIT

Installer's Copy

Permit Issued by **Dave Hylsky - 666-8961**

See EHS field plot plan for location of drainfield and replacement area if attached.

Final Approval of this Permit requires inspection of the system in the ground, uncovered, and submittal of a plot plan distinguishing system construction specifications and final layout including location on the plot with respect to other permanent structures. Please call **(208) 667-9513** to schedule a final inspection of the system prior to covering the system.

NOTE: AT THE TIME OF FINAL INSPECTION, A GREEN OR RED TAG WILL BE TIED TO THE SEPTIC TANK. A GREEN TAG INDICATES SYSTEM IS APPROVED AND READY FOR BACKFILL. A RED TAG INDICATES A PROBLEM AND PHD MUST BE CONTACTED.

Panhandle Health District ENTERED JUN 07 1999
On-Site Sewage System Application 99-28-0328

A site evaluation is not an approval or a permit to install a septic system. Permit approval depends on the following: Site evaluation approval, the predicted maximum daily sewage flow; house size and location; well / spring location; surface water locations; changes to native soil (road grading, benching); distance to neighboring structures (wells, buildings, drainfields); proposed land use; soil quality; other issues of concern.

Permits to construct a septic system are not granted until all such issues are addressed and / or submitted in writing as part of the plot plan / permit application AND found to be consistent with current regulations.

**ISSUED
ANY CHANGES TO THE SITE OR CONDITIONS OF THE APPLICATION AFTER
ISSUANCE OF THE PERMIT MAY RENDER THE PERMIT INVALID.**

Site Evaluation

Site Evaluation & Permit

Permit

Owner's Name

Elsie Krey Matthews

Date

6-7-99

Mailing Address

6060 English Point Rd

Phone # (208) 772-7654

City

Hayden Lake

State I.D.

Zip 83835

Legal Description

T51 R.03 S. 16d6-5AN-3W

Parcel # 02200-008-0107A

Subdivision

Section, Township, Range

Lot 10, 11

Block B

Size _____

(Acres _____)

Location / Directions /
Physical Address

2.5 miles from Point Hayden and 10 miles from Lancaster on
English Point Road

Same as above or

Applicant Name

Mrs. Richard Matthews

1505-437-2562 or local

Mailing Address

1504 Rockwood

Phone # (208) 772-7654 or

City

Albuquerque

State NM

Zip 88310

772-4497-nights or

Applicant is: Landowner Contractor Installer Other

Type of Septic Installation New Replacement

Proposed Use

Individual

Community

(3 to 9 dwellings)

Large Soil Absorption

(2,500 gal / day or 10 or more dwellings)

Is there an existing dwelling on this parcel? Yes No

Description Summer Lake Place

Type of Dwelling

Single Family Residence Commercial _____

Multiple Family Res. Other _____

(For Single & Multiple Family Residences Only)

of Bedrooms 3

of Baths 1 1/2

1/100

Sq. Ft. 1700

of People 2

of Living Units 1

Garbage Disposal Yes No

 Community, Commercial, Large Soil Absorption & Engineered Systems Only

Average Daily Flow _____ Peak Daily Flow _____

6/8/99 DH
17164 ck 90.00

Highlighted Areas Are Required for the Permit Process to be Initiated; All Information Required for Completion